

REPORT DOCUMENTATION PAGE			Form Approved OMB No. 074-0188	
Public reporting burden for this collection of information is estimated to average 1 hour per response, including the time for reviewing instructions, searching existing data sources, gathering and maintaining the data needed, and completing and reviewing this collection of information. Send comments regarding this burden estimate or any other aspect of this collection of information, including suggestions for reducing this burden to Washington Headquarters Services, Directorate for Information Operations and Reports, 1215 Jefferson Davis Highway, Suite 1204, Arlington, VA 22202-4302, and to the Office of Management and Budget, Paperwork Reduction Project (0704-0188), Washington, DC 20503				
1. AGENCY USE ONLY (Leave blank)		2. REPORT DATE 1998		3. REPORT TYPE AND DATES COVERED Proceedings
4. TITLE AND SUBTITLE Diode Laser Measurements of HF Concentrations Produced from Heptane/Air Pan Fires Extinguished by FE-36, FM-200, FE-36 Plus APP, and FM-200 Plus APP			5. FUNDING NUMBERS N/A	
6. AUTHOR(S) R.R. Skaggs, R.G. Daniel, A. W. Miziolek, K.L. McNesby, C. Herud, W.R. Bolt, and D. Horton				
7. PERFORMING ORGANIZATION NAME(S) AND ADDRESS(ES) U.S. Army Research Laboratory, Aberdeen Proving Ground, MD 21005			8. PERFORMING ORGANIZATION REPORT NUMBER N/A	
9. SPONSORING / MONITORING AGENCY NAME(S) AND ADDRESS(ES) SERDP 901 North Stuart St. Suite 303 Arlington, VA 22203			10. SPONSORING / MONITORING AGENCY REPORT NUMBER N/A	
11. SUPPLEMENTARY NOTES No copyright is asserted in the United States under Title 17, U.S. code. The U.S. Government has a royalty-free license to exercise all rights under the copyright claimed herein for Government purposes. All other rights are reserved by the copyright owner.				
12a. DISTRIBUTION / AVAILABILITY STATEMENT Approved for public release: distribution is unlimited.			12b. DISTRIBUTION CODE A	
13. ABSTRACT (Maximum 200 Words) Tunable diode laser absorption spectroscopy (TDLAS) is used to measure the time evolution of hydrogen fluoride (HF) concentrations produced from a series of enclosed heptane/air pan fires extinguished by FE-36, FM-200, FE-35 plus ammonium polyphosphate (APP), or FM-200 plus APP. For the fires studied, the change in HF gas concentration with time is dependent upon the fire fighting chemical used to extinguish the fire. The presence of APP is observed to reduce HF concentrations in the fire enclosure. Visible attenuation spectroscopy is also used to measure the amount of light attenuation (obscuration) that occurs as a hadn held fire extinguisher containing powder fire fighting agent is released in the crew space of a M1-Abrams land combat vehicle.				
14. SUBJECT TERMS SERDP, SERDP Collection, diode laser, HF, TDLAS, fire suppression			15. NUMBER OF PAGES 9	
			16. PRICE CODE N/A	
17. SECURITY CLASSIFICATION OF REPORT unclass	18. SECURITY CLASSIFICATION OF THIS PAGE unclass	19. SECURITY CLASSIFICATION OF ABSTRACT unclass	20. LIMITATION OF ABSTRACT UL	

NSN 7540-01-280-5500

Standard Form 298 (Rev. 2-89)
Prescribed by ANSI Std. Z39-18
298-102

20000720 174

DTIC QUALITY INSPECTED 4

**DIODE LASER MEASUREMENTS OF HF CONCENTRATIONS PRODUCED FROM
HEPTANE/AIR PAN FIRES EXTINGUISHED BY
FE-36, FM-200, FE-36 PLUS APP, AND FM-200 PLUS APP**

R.R. SKAGGS, R.G. DANIEL, A.W. MIZIOLEK, AND K.L. MCNESBY

U.S. Army Research Laboratory, Aberdeen Proving Ground, MD 21005

C. HERUD, W. R. BOLT, AND D. HORTON

U.S. Army Aberdeen Test Center, Aberdeen Proving Ground, MD 21005

ABSTRACT

Tunable diode laser absorption spectroscopy (TDLAS) is used to measure the time evolution of hydrogen fluoride (HF) concentrations produced from a series of enclosed heptane/air pan fires extinguished by FE-36, FM-200, FE-36 plus ammonium polyphosphate (APP), or FM-200 plus APP. For the fires studied, the change in HF gas concentration with time is dependent upon the fire fighting chemical used to extinguish the fire. The presence of APP is observed to reduce HF concentrations in the fire enclosure. Visible attenuation spectroscopy is also used to measure the amount of light attenuation (obscuration) that occurs as a hand held fire extinguisher containing powder fire fighting agent is released in the crew space of a M1-Abrams land combat vehicle.

INTRODUCTION

The mandatory phasing out of halons 1301 (CF_3Br) and 1211 (CF_2ClBr) for use as the primary fire extinguishing agent aboard U.S. Army combat vehicles has led to the testing and evaluation of two candidate replacement agents FE-36 ($\text{C}_3\text{F}_6\text{H}_2$) and FM-200 ($\text{C}_3\text{F}_7\text{H}$). These fluorinated propanes, though effective at extinguishing fires, are deficient in terms of increased weight and volume requirements needed for fighting the most difficult military fires. The increased amounts of replacement agent required for extinguishment, relative to halons 1301 and 1211, pose a concern with the levels of hydrogen fluoride formed as the primary decomposition product. This concern has limited the acceptance of these agents for deployment in occupied spaces.

The two mechanisms by which HF concentrations can be decreased during and following fire extinguishment by FE-36 or FM-200 are by 1) reducing the time required to extinguish the fire, thereby minimizing the time that the fluorine containing suppressant is exposed to flame temperatures, or 2) releasing a scavenging agent in conjunction with the fire suppressant chemical to remove HF after it is produced. A potential chemical scavenging agent of gaseous HF is ammonium polyphosphate (APP), which is a commercially available chemical (Phos-chekTM) with fire retardant properties.

Testing and evaluation of the candidate agents and APP is presented here from full scale fire suppression tests conducted at the Aberdeen Test Center. These tests measure the concentration of the highly toxic and corrosive combustion byproduct gas hydrogen fluoride using near-infrared tunable diode laser absorption spectroscopy (NIR-TDLAS) [1]. A recent article from this laboratory details the use of NIR-TDLAS as the most effective diagnostic for gas phase HF measurements [2]. HF is produced from a series of enclosed heptane [$\text{CH}_3(\text{CH}_2)_5\text{CH}_3$]/air pan fires extinguished by FE-36, FM-200, FE-36 plus APP, or FM-200 plus APP. By measuring how much the HF concentrations are reduced in fires extinguished with FE-36/APP or FM-200/APP mixtures compared to fires extinguished by FE-36 or FM-200 alone, the effectiveness of APP as a HF reduction and potential scavenging agent will be demonstrated. Also, spectroscopic measurements of the amount of light attenuation (obscuration) that occurs as a hand held fire extinguisher containing powder fire fighting agent is released in the crew space of a M1 land combat vehicle will be discussed.

EXPERIMENTAL

Figure 1 shows a schematic diagram of the test facility containing the NIR-TDLAS experimental apparatus and signal processing electronics. TDLAS has proven to be a valuable, non-intrusive optical diagnostic for species concentrations and temperatures in combustion systems even when the local soot level is high [3,4,5,6,7,8,9]. The test facility is a 1.5 m³ cubic enclosure, which contains a liquid heptane pan fire (fire size approximately 30 KW). The fire suppressants used were FE-36 or FM-200. For the extinguishers with APP added, the following

combinations of FE-36 plus APP and FM-200 plus APP were tested: FE-36 plus 7 % APP; FE-36 plus 15 % APP, FM-200 plus 15 % APP.




Figure 1: Schematic diagram of experimental HF measurement apparatus.

The test protocol was as follows: A 250 ml pan filled with heptane fuel was placed underneath 0.5 m high steel table within the cubic container. The NIR-TDLAS HF gas measurement apparatus was situated on top of the metal table where a calibration cell was placed in the line-of-sight path between the GRIN lens from which the 1.3 micrometer laser radiation was emitted and the InGaAs detector. The calibration cell was used to provide a HF spectrum to tune the laser and data collection system. The calibration cell was removed prior to fire testing. A hand held bottle-type extinguisher charged with 770 g FE-36 plus scavenging agent (when applicable) and pressurized with N_2 gas was situated on top of the cubic container. The extinguisher bottle output nozzle was attached via tubing to a spray nozzle protruding into the cubic container.

The heptane pan fire was ignited using a butane electric match and the NIR-TDLAS HF gas measurement was initiated immediately after an internal cubic container fan was turned on and the container door was closed. The heptane pan fire was allowed to burn for 15 seconds at which time the hand held extinguisher's contents were discharged into the interior of cubic container producing total flooding inhibitor conditions (10 % by volume FE-36 concentration). A video camera mounted within the cubic container recorded the fire event during the tests. HF data collection occurred for 180 s after ignition of the fuel, at a rate of 1 spectrum per second.

Following each test, the interior of the cubic container was rinsed with an aqueous solution of sodium bicarbonate to neutralize any acid residues on the interior surface and the container was allowed to air dry. The experimental details and analysis of NIR-TDLAS HF spectra have been described previously² and will only be summarized here.

A sawtooth modulation (≈ 100 Hz) supplied from a Function Generator (Tektronix Model FG 504) was used to rapidly scan over the desired spectral frequency range. Coincident with the 100 Hz modulation was a small amplitude but higher frequency modulation, ≈ 20 KHz, taken from the sine output of a SRS Model 830 DSP Lock-in Amplifier. The application of the two modulations to the laser diode current facilitated wavelength modulation spectroscopy (2f detection) which was needed for enhanced signal sensitivity [10,11,12,13,14]. Wavelength modulation spectroscopy is convenient for analysis because of the linear relationship that exists between the measured absorption signal and the analyte's concentration. Concentrations of HF were calibrated using a

continuous flow cell containing various known mixtures of HF in N₂ and measuring each mixture's unique absorption spectrum.

The emitted infrared light from the diode was launched into a fiber coupled to the laser housing. Fiber optic patch cables were used to deliver infrared light into the test facility. The fiber is terminated by a gradient index (GRIN) lens (Sentech Systems, Inc.), which collimates the laser radiation. The GRIN lens-tipped fiber is placed into a "pitch and catch" arrangement which directs the infrared radiation over a 14 cm open path to a InGaAs detector (Epitaxx Model ETX 1000 T). The signal observed at the detector was directed to a phase sensitive, lock-in amplifier (Stanford Research Systems Model 830) which acquired the 2f absorption signal. The 2f output signal from the SRS lock-in amplifier was then sent to a digital oscilloscope (LeCroy Model 9654). Resulting spectra were acquired every second for a three minute time period and then sent to a Pentium based laptop computer for storage and analysis. For experiments described here, the P(2) transition of the first vibrational overtone of HF was monitored at 7665 cm⁻¹ [5].

Figure 2 presents a schematic representation of the experimental apparatus used for attenuation testing. The apparatus consists of a HeNe laser (Oriel Model 6611 output 632 nm), an Optical Chopper (Stanford Research Systems Model SR540), and a fiber optic fiber coupler (Newport Optics Model F-916T). The experimental equipment was mounted to a 46 x 46 cm optical bread board which was placed outside the crew compartment on top of the vehicle. A separate 41 cm optical rail supported the fiber collimating/ projection optics and a 15 mm² (active element) photodetector (Centro Vision Inc. OSD5-5T, 350-1100 nm). The optical rail was placed inside the vehicle in the driver's seat. Not shown is a plastic enclosure that was placed over the fiber collimating/projection optics to minimize the optic devices from exposure to the powder agent. A 18 m BNC cable and extension cord provided remote signal communications and power to the chopper and laser while another 18 m BNC cable transported the detector signal out to the detection electronics. The tests consisted of an occupant releasing a Kidde™ 2.75lb hand held fire extinguisher containing either FE-36 plus APP or NaHCO₃ plus N₂ at the personnel heater while inside the vehicle and all outside hatches were closed. With the hatch doors closed, the vehicle's nuclear and biological containment (NBC) system was operated to create a positive pressure inside the crew compartment.




Figure 2: Schematic diagram of light attenuation measurement apparatus

Light attenuation is determined by monitoring the percent transmission of HeNe laser radiation that is incident on the detector as chemical agent is dispersed over the measurement region. Thus, if 100 % transmission occurs, all the light that exits the laser source is incident upon the detector and no attenuation occurred. The laser radiation is passed through an optical chopper, which modulates the laser radiation at ≈ 1000 Hz. After passing through the chopper, the laser radiation is launched into a 8m long visible fiber optic cable (3M™ multi-mode, 1000 mm diameter core, glass substrate optical fiber). Light passes out the opposite end of the fiber where it is terminated into a 11 mm SMA fiber ferrule (Oriel Model 77670). The terminated fiber is inserted into a glass collimating beam probe (Oriel Model 77645). The collimated light exits the beam probe and is directed into a visible Nikon™ objective lens, which apertures the beam to approximately 5-6 mm and directs it over a 0.4 m free space where the laser radiation is incident onto the 15 mm² photodetector. The free space through which the laser radiation passes is the region in which the powdered agent, if present, will attenuate the laser radiation. The light intensity reaching the detector is converted to a voltage, which is then measured using a lock-in amplifier referenced to the chopper frequency. A DC voltage (0-5 V full scale), proportional to the detector signal, is output to the digital oscilloscope (LeCroy Model 9654), which is also triggered by the optical chopper, and is processed and recorded using a Pentium based laptop computer at a rate of 2 Hz.

RESULTS

Figure 3 presents average HF concentration profiles from extinguishment tests with FE-36, FE-36 plus 7 % APP, FE-36 plus 15 % APP, FM-200, and FM-200 plus 15 % APP. For the FE-36 plus 7 % APP and FE-36 plus 15 % APP tests, three individual profiles for each extinguisher concentration were used to construct each test's average profile.




Figure 3: Average HF concentration profiles versus measurement time. The () symbols are HF concentrations from fires extinguished by FE-36, the () symbols are HF concentrations from fires extinguished by FE-36 plus 7 % APP, the (+) symbols (bottom trace) are HF concentrations from fires extinguished by FE-36 plus 15 % APP, the (.) symbols are HF concentrations from fires extinguished by FM-200, and the () symbols are HF concentrations from fires extinguished by FM-200 plus 15 % APP.

For the FE-36 profile, test data from five different profiles, collected over the entire testing period, compose the average profile. The FM-200 only average profile is constructed from 10 separate tests while the FM-200 plus 15 % APP profile consists of four separate tests. Statistically the 1 σ variances for the profiles were 41, 42, 31, 56, and 54 percent for FE-36, FE-36 plus 7% APP, FE-36 plus 15 % APP, FM-200, and FM-200 plus 15 % APP. For the FM-200 and FM-200 plus APP tests, the large statistical deviations are attributed to inconsistent fire extinguishment

times (explained in more detail below) from test to test, which was not as evident in the FE-36 tests. **Table I** lists the maximum HF concentrations and time weighted averages from each profile in **Figure 3**.

Table I: Maximum HF concentrations (ppm) and time weighted average HF concentration (ppm)

	FE-36	FE-36 + 7 % APP	FE-36 + 15 % APP	FM-200	FM-200 + 15 % APP
HF Maximum, ppm	1394	996	73	2667	1638
HF TWA, ppm	712	493	23	1626	646

The results from **Figure 3** and **Table I** indicate that fires extinguished by FM-200 produce almost twice as much HF as fires extinguished by FE-36. For fires extinguished by FE-36 plus APP or FM-200 plus APP, the data show that HF is reduced with respect to fires extinguished by the neat agents alone. **Table I** also lists the time weighted average HF values which represent the average dose of HF one would be exposed to from the time of extinguisher release at $t = 15$ seconds until the end of the measurement period, $t = 180$ seconds. The time weighted average is very important because the primary toxicity concern for HF exposure is not the maximum HF one experiences but the average concentration one is exposed to over a period of time. It should be noted that the target non-toxic HF TWA level for these tests was 500 ppm or less. From **Table I** the HF TWA values imply that for the tests with FE-36, FM-200, and FM-200 plus 15 % APP the HF dose is toxic, while the tests with FE-36 plus 7% APP and FE-36 plus 15 % APP achieve minimum to very acceptable HF reductions respectively.

Measurement of HF gas concentration versus time provides a monitor of the fire history, and of the effectiveness of any HF reduction agent used. That is, the time from fire suppressant release until the maximum HF concentration occurs is a measure of the time required for fire extinction (also verified visually using a video recorder), while the rate at which the HF concentration decreases following extinguishment provides a measure of the effectiveness of scavenging agent (when used), or a measure of the rate at which HF gas reacts with the walls of the enclosure. Reduction in fire out times reduces HF levels by reducing the time the agent is exposed to flame temperatures which causes agent decomposition to HF. **Table II** lists the fire out times from **Figure 3**.

Table II: Fire out times (seconds) from average profiles in Figure 3

	FE-36	FE-36 + 7 % APP	FE-36 + 15 % APP	FM-200	FM-200 + 15 % APP
Fire Out Times	18	20	12	20	12

Statistically the difference in fire out times between fires extinguished by FE-36 and FE-36 plus 7 % APP are insignificant with a 1σ error of 22 percent. For fires extinguished by FE-36 plus 15 % APP and FM-200 plus 15 % APP, the fire out times were reduced by approximately 33 to 40 percent relative to the fires extinguished by the respective neat agents themselves. The decrease in the TWA HF levels in **Table I** for fires extinguished using FE-36 and FM-200 compared to fires extinguished by FE-36 plus 15 % APP and FM-200 plus 15% APP (approximately a factor of 30 and 2.5 respectively) is partially attributable to the fire suppression properties of APP (reflected by the shorter fire out times).

Figure 3 and **Table I** indicate that the presence of APP, regardless of the percentage in the extinguisher, helps reduce the overall HF levels with respect to those fires extinguished by only neat agents. A possible explanation for the HF reductions is that without APP in the enclosure, fires extinguished by the neat agents are able to produce HF more rapidly than fires extinguished by neat agents plus APP. This statement is supported by **Figure 4** that plots HF concentrations for each extinguisher from $t = 16$ seconds until $t = 31$ seconds which are the time locations from the extinguisher release to just before the HF concentrations reach their respective maximums in **Figure 3**. Linear regression analysis of this data indicates that FM-200 produces HF 39 percent faster than FE-36. For the fires extinguished by FE-36, HF is formed 21 percent faster than the fires extinguished by FE-36 plus 7 % APP while fires extinguished by FM-200 form HF 12 percent quicker than those fires extinguished by FM-200 plus 15 % APP. Obviously the data in **Figure 4** is dependent on the fire out times and previous studies [15] have shown that as the fire out times increase this is accompanied by an increase in the amount of HF present in the system.




Figure 4: Plot of HF concentrations versus measurement time from $t = 16$ seconds to $t = 31$ seconds to illustrate HF production rates. The () symbols are HF concentrations from fires extinguished by FE-36, the () symbols are HF concentrations from fires extinguished by FE-36 plus 7 % APP, the (+) symbols are HF concentrations from fires extinguished by FE-36 plus 15 % APP, the (,) symbols are HF concentrations from fires extinguished by FM-200, and the () symbols are HF concentrations from fires extinguished by FM-200 plus 15 % APP. The straight solid lines represent linear regression analysis of the data.

In real fires reduction of fire out times are difficult to control, and if the time duration is extended some measures must be taken to control the HF levels. APP is added to these extinguishers because it is believed that APP can heterogeneously scavenge HF from the post flame gases of a fire situation extinguished by a fluorinated fire fighting agent. To evaluate APP's scavenging abilities, the time rate of change of the HF concentration must be measured.

The rate of change in HF concentration can be compared between extinguishers with and without APP using data from **Figure 3** starting at the maximum HF concentration time (t_0) and plotting the natural logarithm of the HF concentration versus the natural logarithm of the elapsed time from the HF maximum, as seen in **Figure 5**.




Figure 5: Rate plot of \ln (HF) concentrations versus \ln (time) for fires extinguished by FE-36 only (), FE-36 plus 7 % APP (), FM-200 (+), FM-200 plus 15 % APP (,). The straight solid lines represent linear regression analysis of the data.

As the HF concentration for tests with FE-36 plus 15 % APP were well below the target concentration of 500 ppm, no further analysis of the data was warranted as well as the fact that the discharged APP concentration probably exceeded acceptable respiratory exposure levels [16]. Figure 5 being on a ln-ln scale indicates that the dissipation of HF versus time is a second order decay process. Results from linear regression analysis of the data in Figure 5 are presented in Table III.

Table III: Slope (ppm/second) values from linear regression analysis of HF dissipation rates

	FE-36	FE-36 + 7 % APP	FM-200	FM-200 + 15 % APP
Slopes (ppm/second)	-0.65	-0.75	-0.52	-0.55

The difference in slopes for between FE-36 and FE-36 plus 7 % APP tests is approximately 13 percent greater for the fires extinguished by FE-36 plus 7 % APP, while the difference between the FM-200 and FM-200 plus 15 % APP is approximately 5 percent. Thus the faster decreases in HF concentrations from fires extinguished by FE-36 plus APP and FM-200 plus APP versus FE-36 and FM-200 respectively is attributed to the presence of APP.

The primary concern with combining a powder substance like APP in a hand held extinguisher with the fluorinated agents is when the extinguisher contents are released the powder is temporally suspended in the air forming a visibly dense "cloud" that could be difficult to see through. To address and quantify this situation, a series of obscuration measurements were conducted. Figure 6 presents results from the obscuration measurements with temporally resolved percent transmission profiles measured during and following the release of the FE-36 plus APP and the NaHCO_3 plus N_2 extinguishers inside a M1-Abrams combat vehicle.




Figure 6: Percent transmission profiles collected from measurement of light attenuation while an extinguisher containing either FE-36 plus APP (solid line) or FE-36 plus NaHCO_3 (dashed line) was released inside an M1 combat vehicle. The horizontal line drawn across the graph is the 70 % transmission level which corresponds to the minimal level of clear visibility to the human eye.

The profiles indicate that the maximum light attenuations were 0 percent transmission for the NaHCO_3 plus N_2 extinguisher and 18 percent transmission for the FE-36 plus APP extinguisher. Empirical correlations using a VHS video taken inside the vehicle during the extinguishers discharge indicate that clear visibility to the human eye correlates to an attenuation level of approximately 70 percent transmission. Thus, all percent transmission levels recorded below 70 percent transmission correspond to an obscured field of view at a distance of 30.48 cm. The time

duration that visibility is less than 70 percent transmission for the NaHCO_3 extinguisher is 63 seconds while the FE-36 plus APP extinguisher experiences less than 70 percent transmission for 49 seconds. The more rapid return to visibility, i.e. ≥ 70 percent transmission, using the FE-36 plus APP extinguisher is attributed to the fact that the powder is not released in a dry state, rather it is "wet" and thus falls faster to the vehicle floor.

CONCLUSIONS

NIR-TDLAS has been demonstrated to measure HF in a practical field application. The results presented here indicate that HF concentrations produced from fires extinguished by FE-36 plus APP and FM-200 plus APP are being reduced in the cubic test container and that the presence of APP accelerates this reduction. Thus the combination of APP in an extinguisher containing FE-36 or FM-200 appears to reduce HF levels. Visibility reduction during extinguisher deployment was measured inside an actual combat vehicle for extinguishers containing FE-36 plus APP and NaHCO_3 plus N_2 . From an experimental standpoint, more tests should probably be conducted to analyze the reacted APP to understand how APP reacts with HF. Future tests will attempt to meet this concern in order to develop a chemical kinetic mechanism for post fire HF activity.

ACKNOWLEDGMENTS

For the light attenuation experiments, the authors would like to thank Dave Roberts (International Imaging Systems of ATC) for VHS filming, Jeff Morris (ARL) for loan of the SRS optical chopper, and Edwin Lancaster (ARL) for fabrication of the fiber optic cable. The HF testing was financially supported by the U.S. Army TACOM (Steve McCormick) and POWSUS Inc. (Harry Stewart and Don MacElwee). Finally R. Skaggs would like to acknowledge financial support from the Army Research Laboratory through an American Society for Engineering Education Postdoctoral Fellowship.

REFERENCES

1. K.L. McNesby, R.G. Daniel, J.M. Widder and A.W. Miziolek , *Applied Spectroscopy* 50: p. 126, (1996).
2. K.L. McNesby, R.R. Skaggs, A.W. Miziolek, M. Clay, S. Hoke, and C.S. Miser, *App. Phys. B*, 67: p. 443, (1998).
3. R.K. Hanson, *Appl. Opt.* 19: p. 482, (1980).
4. P.L. Varghese and R.K. Hanson, *J. Quant. Spect. and Rad. Trans.* 24: p.479., (1980).
5. S.M. Schoenung and R.K. Hanson, *Combust. Sci. and Technol.* 24: p. 227, (1981).
6. J.H. Miller, S. Elreedy, B. Ahvazi, F. Woldu, and P. Hassanzadeh, *Appl. Opt.*, 32: p. 6082, (1993).
7. Q.V. Nguyen, B.L. Edgar, R.W. Dibble, and A. Gulati, *Combust. and Flame* 100: p.395, (1995).
8. R.R. Skaggs and J.H. Miller, *Combust. and Flame*, 100: p. 430, (1995).
9. R.R. Skaggs and J.H. Miller, *Twenty-Sixth (Intl.) Symposium on Combustion*, The Combustion Institute, Pittsburgh, p. 1181, (1996).
10. J. Reid and D. Labrie, *Appl. Phys. B* 26; p. 203, (1981).
11. D.T. Cassidy and J. Reid, *Appl. Opt.* 21 p. 1186, (1982).
12. D.M. Bruce and D.T. Cassidy, *Appl. Opt.* 29, p. 1327, (1990).
13. J.A. Silver, D.S. Bomse, and A.C. Stanton *Appl. Opt.* 30, p. 1505, (1991).
14. D.S. Bomse, A.C. Stanton, and J.A. Silver, *Appl. Opt.* 31, p.718 (1992).
15. R.R. Skaggs, R.G. Daniel, A.W. Miziolek, and K.L. McNesby, C. Herud, W. Bolt, and D. Horton, *Proceedings of the SPIE Fall Meeting: Photonics East Environmental and Industrial Monitors*, *in press*, (1998).
16. POWSUS, Inc, Private Communication, (1998).